

# Dry Creek WWTP Local Limits

---

<u>Pollutant</u>	<u>Daily Maximum (mg/L)</u>
Arsenic	2.21
Cadmium	0.12
Chromium, total	6.00
Chromium, hexavalent	1.15
Copper	3.06
Cyanide, free	0.69
Lead	0.76
Mercury	0.0005
Nickel	4.55
Selenium	0.23
Silver	1.0
Zinc	3.50

*See Sanitation District No. 1 Wastewater Rules and Regulations for more information.*

# Eastern Regional WRF Local Limits

---

<u>Pollutant</u>	<u>Daily Maximum (mg/L)</u>
Arsenic	1.02
Cadmium	0.02
Chloride	2,000
Chromium, total	3.80
Chromium, hexavalent	0.23
Copper	0.29
Cyanide	0.03
Lead	0.11
Mercury	0.0005
Nickel	0.82
Selenium	0.03
Silver	0.35
Zinc	1.36

*See Sanitation District No. 1 Wastewater Rules and Regulations for more information.*

# Western Regional WRF Local Limits

---

<u>Pollutant</u>	<u>Daily Maximum (mg/L)</u>
Arsenic	1.44
Cadmium	0.052
Chromium, total	6.00
Chromium, hexavalent	0.84
Copper	1.48
Cyanide, amenable	0.21
Lead	0.608
Mercury	0.0005
Nickel	4.91
Selenium	0.572
Silver	0.307
Zinc	3.94

*See Sanitation District No. 1 Wastewater Rules and Regulations for more information.*